



1 FLOOR PLAN  
SCALE: 1:100

AD4

**GENERAL NOTES:**

- A. DIMENSIONS ARE SHOWN TO OUTER EDGE OF EXTERIOR STRUCTURAL COLUMNS, STRUCTURAL COLUMN GRID, EDGE OF INTERIOR PARTITIONS, EDGE OF WINDOW OPENINGS, AND TO HINGED SIDE OF DOOR FRAME OPENINGS.
- B. HINGE SIDE OF OPENINGS FOR DOORS AND FRAMES SHALL BE LOCATED 200 MM FROM THE ADJACENT WALL OR COLUMN, UNLESS NOTED OTHERWISE.
- C. INTERIOR PARTITIONS SHALL BE 200 MM CMU. SEE STRUCTURAL DRAWINGS FOR LOCATION OF CONCRETE SHEAR WALLS.
- D. COSMETIC REPAIR OF MINOR DEFECTS: REPAIR OR FILL MORTAR JOINTS AND MINOR DEFECTS, INCLUDING BUT NOT LIMITED TO SPALLS, IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS AND PRIOR TO COATING APPLICATION. SURFACES TO BE PAINTED SHALL BE CLEAN AND FREE OF FOREIGN MATTER BEFORE APPLICATION OF PAINT. CLEANING SHALL BE SCHEDULED SO THAT DUST AND OTHER CONTAMINANTS WILL NOT FALL ON NEWLY PAINTED SURFACES.
- E. PLASTER AND MASONRY SURFACES SHALL BE ALLOWED TO CURE FOR AT LEAST 30 DAYS BEFORE PAINTING. CONCRETE SLABS-ON-GRADE SHALL BE ALLOWED TO CURE 90 DAYS BEFORE STAINING OR SEALING.
- F. DO NOT USE PAINT MATERIALS CONTAINING LEAD CONTENT IN EXCESS OF 0.009 PERCENT OF THE WEIGHT OF THE TOTAL NONVOLATILE CONTENT OF THE PAINT OR THE WEIGHT OF THE DRIED PAINT FILM.
- G. DO NOT USE ANY ASBESTOS CONTAINING MATERIALS (ACM) IN PROJECT. ACM IS DEFINED AS 1% OR MORE BY VOLUME.
- H. DO NOT USE PAINT MATERIALS CONTAINING MERCURIAL FUNGICIDES.
- I. FACTORY PRIMED METAL DOORS AND FRAMES SHALL RECEIVE TWO COATS OF PAINT.
- J. FILL REMAINING SPACE AT PENETRATIONS IN FIRE-RATED FLOORS, PARTITIONS AND CEILINGS WITH APPROPRIATE FIRESTOPPING MATERIALS.
- K. ALL CEILING FINISHES SHALL BE PAINTED PLASTER APPLIED TO STRUCTURE.
- L. ALL WALL FINISHES SHALL BE PAINTED PLASTER APPLIED TO STRUCTURE, UNLESS NOTED OTHERWISE.
- M. ALL FLOOR FINISHES SHALL BE EPOXY SEALED CONCRETE, UNLESS NOTED OTHERWISE.
- N. PROVIDE TILE FINISHES AS INDICATED IN DETAILS.
- O. ALL DOOR, FRAME AND HARDWARE TYPES SHALL BE 20A.1.6 UNLESS NOTED OTHERWISE.
- P. TOILETS STALL DOOR, FRAME & HARDWARE TYPE SHALL BE F.2.12.
- Q. PROVIDE POLISHED STAINLESS STEEL MIRROR 600 X 900 ABOVE LAVATORY FAUCET.

**KEY NOTES:**

1. LINE OF ROOF OVERHANG ABOVE.
2. CONCRETE STOOP - SEE DETAIL 3/A-503.
3. ISOLATION JOINT COVER- SEE SHEET A-505.
4. CONCRETE STOOP WITH GRATE - SEE DETAIL 1/A-503.
5. NOT USED.
6. GRATE - SEE SIMILAR DETAIL 1/A-503.

**LEGEND:**

- XXX DOOR FRAME AND HARDWARE TYPE, SEE SHEET A-601
- ◊ WINDOW TYPE, SEE SHEET A-601
- X KEY NOTE

**ABBREVIATIONS:**

- COMM COMMUNICATIONS
- ELEC ELECTRICAL
- MECH MECHANICAL
- JAN JANITOR
- CLOS CLOSET

APPROVED: \_\_\_\_\_  
 ALL DESIGNER OF RECORD  
 SEAL: \_\_\_\_\_

LINEAR DIMENSIONS SHOWN ARE IN MILLIMETERS (MM), UNLESS OTHERWISE NOTED

0 2000 4000  
SCALE: 1:100



Date	Issue	Description

U.S. ARMY CORPS OF ENGINEERS AFGHANISTAN ENGINEER DISTRICT Michael Blair, P.E., PE Project Engineer LHM Approved by:	Date: 2/23/10 Design file no. Drawing code: Revision: File name: 100100000 File date: 10/03/09
---	---

STANDARD DESIGN  
 VARIOUS LOCATIONS, AFGHANISTAN  
 RMC HEADQUARTERS BUILDING  
 FLOOR PLAN

Sheet reference number:  
**A-101**