

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE OF PAGES	
				J	1	2
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 28-Feb-2010	4. REQUISITION/PURCHASE REQ. NO. AIRBORNE		5. PROJECT NO. (If applicable)	
6. ISSUED BY AFGHANISTAN DISTRICT NORTH (AEN) US ARMY CORPS OF ENGINEERS OPERATION ENDURING FREEDOM APO AE 09356		CODE W5J9JE	7. ADMINISTERED BY (If other than item 6) See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X	9A. AMENDMENT OF SOLICITATION NO. W5J9JE-10-R-0030	
				X	9B. DATED (SEE ITEM 11) 02-Feb-2010	
					10A. MOD. OF CONTRACT/ORDER NO.	
					10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.						
<p>Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:</p> <p>(a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACT/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) W5J9JE-10-R-0030, Re-Locatable Buildings (RLBs) at FOB Airbone, Wardak, Afghanistan The purpose of this amendment is to extend the due date of proposals to 03:00 PM local Kabul time on 6 March 2010. It also revises Section 01010 as specified in the continuation page.						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
			TEL:		EMAIL:	
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)			BY _____ (Signature of Contracting Officer)		28-Feb-2010	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

(End of Summary of Changes)

The following items are applicable to this modification:

Airborne RLB RFP Section 01010 is amended as follows.

Para 4.12. "ELECTRICAL"

Remove this paragraph, it is redundant.

Para 4.4. "SITE ELECTRICAL DISTRIBUTION SYSTEM"

Current paragraph:

POWER SYSTEM: The contractor shall design and construct a power system for supply and distribution to all buildings to include generators with fuel storage, and underground electrical distribution. All electrical design and installation shall meet the current NEC (NFPA 70) requirements. Electrical design shall be as indicated in Section 01015, TECHNICAL REQUIREMENTS. Conductors and circuits shall be sized for the specific loads. All wiring shall be run and pulled through conduits. Contractor must verify the existing electrical switchgear that will be used to supply the RLB installation. The site electrical distribution system shall include a fused electrical service disconnect rated at the voltage and current ampacity of the feeder that is supplying the RLB installation. The new electrical supply and distribution system must match the existing system. The new electrical system shall be designed as described in the section 01015, TECHNICAL REQUIREMENTS and the switchgear canopy shall consist of a shelter with just a roof. Lockable electrical enclosures suitable for outdoor operation and that are marked with CE markings or that are UL approved shall be installed under the switchgear canopy.

Shall be Changed to Read:

POWER SYSTEM: The contractor shall design and construct an underground electrical distribution system to provide power to all buildings. This system shall include provisions to connect to a future power source (by others). All electrical design and installation shall meet the current NEC (NFPA 70) requirements. Electrical design shall be as indicated in Section 01015, TECHNICAL REQUIREMENTS. Conductors and circuits shall be sized for the specific loads. All wiring shall be run and pulled through conduits. Contractor must verify the existing electrical switchgear that will be used to supply the RLB installation. The site electrical distribution system shall include a fused electrical service disconnect rated at the voltage and current ampacity of the feeder that is supplying the RLB installation. The new electrical supply and distribution system must match the existing system. The new electrical system shall be designed as described in the section 01015, TECHNICAL REQUIREMENTS and the switchgear canopy shall consist of a shelter with just a roof. Lockable electrical enclosures suitable for outdoor operation and that are marked with CE markings or that are UL approved shall be installed under the switchgear canopy.