

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 10-May-2010	4. REQUISITION/PURCHASE REQ. NO. W5J9JE10R0063		5. PROJECT NO.(If applicable) 1
6. ISSUED BY AFGHANISTAN DISTRICT NORTH (AEN) US ARMY CORPS OF ENGINEERS OPERATION ENDURING FREEDOM APO AE 09356	CODE W5J9JE	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W5J9JE-10-R-0063	
		X	9B. DATED (SEE ITEM 11) 16-Apr-2010	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. <p>Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:          (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;          or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  W5J9JE-10-R-0063 is amended to delay the receipt of proposals to May 23, 2010 at 3:00 p.m. Kabul time. There will be another amendment forthcoming to give updated coordinates reflecting a slight change in the site.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		10-May-2010

**W5J9JE-10-R-0063 Ammo Bunkers at Pol-e-Charki Requests for Information**  
**2<sup>nd</sup> Set of RFIs**

1. Although SOW does not contain perimeter wall, we have seen the details of perimeter wall in section 01015 para 2.3.5.1 and sheet reference number C7 in Appendix A-2. Hence, we are confused whether perimeter wall is included in the SOW or not. If yes, can you please inform us about the length of perimeter wall and where to allocate it in proposal schedule.

SOW includes demo and reconstruction of the wall within the current limits of the compound to install the ECP upgrades. It is the contractor's responsibility to design the ECP and new perimeter wall meeting the requirements in the RFP.

2. In paragraph 4.3.6.1 of SOW, it is stated that states that: "A portion of the existing perimeter security wall shall be demolished in order to upgrade the ECP and provide a rejection lane". Can you please inform us about the length of perimeter wall which will be demolished for that purpose.

SOW includes demo and reconstruction of the wall within the current limits of the compound to install the ECP upgrades. It is the contractor's responsibility to design the ECP and new perimeter wall meeting the requirements in the RFP.

3. Please refer to dwg E-1 and kindly specify the Air Terminal Units (class, flow rate etc.)

Ventilation is passive only.

4. Please refer to dwg S-6 and kindly specify the Ventilators (class, flow rate, type, pressure etc)

Ventilation is passive only.

5. Please kindly confirm if Guard Shack and Guard Tower will have no heating or cooling systems.

No heating systems. Cooling consists only of ceiling fan as shown on provided plans.

6. Please kindly confirm that Munitions Storages will have no humidity control.

There is no humidity control only the passive ventilation system.

7. Is the lighting fixtures inside the ammo-bunkers are explosion proof or not?

Lighting fixtures are to be explosion proof.