

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 12-Jun-2011	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) PFBW040701/2
6. ISSUED BY AFGHANISTAN DISTRICT SOUTH (AES) US ARMY CORPS OF ENGINEERS APO AE 09355	CODE W5J9LE	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W5J9LE-11-R-0054	
		X	9B. DATED (SEE ITEM 11) 21-May-2011	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Project: Construction of Two (2) Class B Fire Stations in Herat City, Herat Province. Herat Sites #2 & #3. PN: PFBW040701 & 02 Contracting POC: evan.b.carter@usace.army.mil Questions and Answers pt. 2				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		11-Jun-2011

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION 00800 - SPECIAL CONTRACT REQUIREMENTS

The following have been added by full text:

Q&A 2

Q&A Pt. 2

Q3. Please confirm there is only one 200KVA generator, the power plant drawing shows two generators.

A3. See Below.

Q8. According to the Single Line Diagram for Electrical System (Drawing 00-E-601), there are two (2) Diesel Generators 810kVA/648 kW and related equipment, but in the Scope of Work, there is mention of only one. Please Clarify.

A8. See Below.

Q9. According to the Single Line Diagram for Electrical System (Drawing 00-E-601), there is one (1) Utility Distribution Transformer 800kVA, 11kV/380V and related equipment, but in the Scope of Work, this Transformer is not mentioned. Please Clarify.

A9. See Below.

Q13. Scope of work section 01010pra 4.11.1 specified to provide one 200KVA generator, but in drawing page 00-E-103 two sets of generator have shown. Please clarify; should we calculate two or one set of generator?

A13. See Below.

Section 01010

4.11.1 ON-SITE POWER PLANT

Delete – “Power Plant shall consist of one 200kVA generator for each project site in accordance with the requirements indicated in Section 01015. Generator shall be provided with the manufacturer's weather-proof sound attenuating enclosure. Generator pad, overhead cover, and security fencing shall be constructed in accordance with the provided contract Fuel Generator Canopy and drawings with fencing and lockable gates. All fencing and gates shall be topped with triple strand barb wire.”

Add – “Power Plant shall be designed in accordance with the requirements indicated in Section 01015.”

Section 01015

9.4.1 Electrical Distribution System

Generator Power System

Delete – “The generator power system shall consist of one 200 kVA generator. The generators shall supply power at 380/220 V, 50 Hz. Generators shall be derated as necessary for the ambient temperature and altitude of the site.

Generator fuel storage capacity shall be based on usage at total load for a minimum of 30 days. For fuel storage requirements, see Mechanical paragraph: Generator Fuel Storage/Distribution.”

Add – “The generator system shall consist of two 810kVA generators as shown in the electrical single-line diagram. All electrical apparatus, including the 800 kVA transformer and the disconnect switch for future utility connection, shall be installed as shown in the single-line diagram. Each generator shall have a net rating of 810kVA after being de-rated for the altitude and temperature of the site.

A load bank rated at 40% of the nameplate rating of the generator shall be installed at the main switchboard, MSWB, panel. The load bank shall have 50kW or less load steps and shall be connected to the MSWB via a circuit breaker.

Generator shall be provided with the manufacturer's weather-proof sound attenuating enclosure. Generator pad, overhead cover, and security fencing shall be constructed in accordance with the provided contract Fuel Generator Canopy and drawings with fencing and lockable gates. All fencing and gates shall be topped with triple strand barb wire.

Generator fuel storage capacity shall be based on usage at total load for a minimum of 30 days. For fuel storage requirements, see Mechanical paragraph: Generator Fuel Storage/Distribution.”

(End of Summary of Changes)