

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. 0006		3. EFFECTIVE DATE 01-Mar-2012	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) PSPS060801PS
6. ISSUED BY AFGHANISTAN DISTRICT SOUTH (AES) US ARMY CORPS OF ENGINEERS APO AE 09355		CODE W5J9LE	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. W5J9LE-12-R-0024	
			X	9B. DATED (SEE ITEM 11) 02-Jan-2012	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  Project No: PSPS060801PS - Ministry of Interior Supply Point @ Qalat.  The purpose of this amendment is to provide additional responses by the Government to questions received. The cut-off date of seven (7) days prior to the due date of proposals for offerors questions/inquiries is now passed. No further response will be provided by the Government.  The proposal due date of 7 March 2012 @ 5:00 pm remains unchanged.  See continuation page, block 14 for detail.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			BY _____ (Signature of Contracting Officer)		

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

The following have been added by full text:

Questions & Responses Amendment 0006 – W5J9LE-12-R-0024

(See Amendment 0003 for previous questions and answers)

Q15: Section 01015 (Technical Requirements) at page “01015 - 63 of 70” and Subsection 8.6.1.1 “Generation Power System” results in a calculated generator capacity of 120 KW (150 Kva ) based upon 1 KW per person +20% for a population of 100 persons. The resulting cumulative Demand Load for the complete project, as per the supplied panel schedule, is 768 KVa; this agrees with the VA reported in the drawings of the buildings contained in the Project Site Plan. Please advise concerning the size (KV a Capacity) of the Generator to be installed.

R15: The contractor shall size the electrical distribution system such as feeders, panels, circuit breakers, etc per the standard drawings. Everything downstream the generator shall be sized based on the standard drawings. The 120kW generator requirement per the RFP meets the diversified demand load requirements of the site and is adequate.

Q16: Please confirm item number 0003AS – ECP Canopy has been omitted from the proposal schedule list per amendment 0003.

R16: Confirmed. ECP canopies have been removed from scope. Amendment 0005 contains the current proposal schedule the offeror must use in their proposal submission.

Q17: Please confirm the Senior Barrack, item 0005AE is a single story building, not a two building as the drawing on pages 46 and 47 of Appendix A Part2/5 shows.

R18: The Senior Barrack is a two story building as shown on the drawings. The quantity of the Senior Barrack is 1 as shown in the Proposal Schedule item 0005AE.

(End of Summary of Changes)