

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 23-Feb-2012	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) O&M12-011, 015 & 016
6. ISSUED BY AFGHANISTAN DISTRICT SOUTH (AES) US ARMY CORPS OF ENGINEERS APO AE 09355		CODE W5J9LE	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. W5J9LE-12-R-0038	
			X	9B. DATED (SEE ITEM 11) 01-Feb-2012	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) O&M 12-011/12-016 & 12-017, ANA NAVC Sites - Daykundi, Uruzgan & Zabel The purpose of this amendment is to provide Government responses to offerors questions. See continuation page, block 14 for additional detail. The proposal due date is extended to 4 March 2012 @ 5:00 pm. Proposals will be submitted to Richard Horton via email at richard.d.horton@usace.army.mil with a courtesy copy to tas.contracting@usace.army.mil Any further electronic (as email) inquiries to this solicitation must be received by this office not later than 27 February 2012. Inquiries will be sent to richard.d.horton@usace.army.mil with a courtesy copy to tas.contracting@usace.army.mil. Inquiries received after that date will not receive a response by the Government. Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			BY _____ (Signature of Contracting Officer)		

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

The following have been added by full text:

Response to questions for NAVC Solicitation W5J9LE-12-R-0038

Q1: The subject project Scope of work page # 58, 63 and 68 clearly indicates about New concrete drive way. The drawing also indicates new concrete drive way. But the pricing schedule doesn't contain item for concrete drive way. Should we include this as a separate item? Please advise.

R1: Please see paragraphs 2.3.2 and 4.3 in Section 01010 of the solicitations:

- Paragraph 2.3.2, "Construction Design Submittal"

This paragraph indicates that the concrete drive way shall be part of the 'Main Entry Gate' construction.

- Paragraph 4.3, "Main Entry Gate"

This paragraph references a group of paragraphs that are to be included in the CLIN for the Main Entry Gate. One of the referenced paragraphs is 'Concrete Driveway'.

Please include the cost of the concrete driveways in the CLIN for the Main Entry Gate for all projects in this solicitation.

Q2: in the SECTION 00100 SOLICITATION SCHEDULE did not provided any Item for Design cost, do we provide any cost for design?

R2: All design cost shall be included in the CLIN for that item. This is indicated in the paragraphs for the individual items.

Q3: What do you mean by security in page 3 of 49 item 0001AB.

R3: The cost for security shall be included according to the paragraph titled "Security" in Section 01010 and in Section 01040 of the solicitations.

Q4: I want to get information about STANDARD 8'X10' TWO STORY CONNEX GUARD TOWER, I review all drawings but couldn't find search light in guard tower Kindly let us know is there search light in guard tower? And the Aluminum sliding window is made of simple glass or bullet proof (Plexiglas) type?

R4: This solicitation does NOT require the guard tower to be electrified. Please refer to sheet A1 of the standard design for the Two Story Connex Guard Tower, the window material is called out as "0.6cm tinted Plexiglas".

(End of Summary of Changes)