

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO. 0007	3. EFFECTIVE DATE 17-Aug-2007	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) 1   3
6. ISSUED BY AFGHANISTAN ENGINEER DISTRICT US ARMY CORPS OF ENGINEERS KABUL APO AE 09356	CODE W917PM	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W917PM-07-R-0086	
		X	9B. DATED (SEE ITEM 11) 12-Jul-2007	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  This amendment is to answer questions from prospective offerors and to state; that amendment 0006 pertained to Kunduz only (W917PM-07-R-0086) and to state that no further questions will be entertained.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		17-Aug-2007

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

QUESTIONS & ANSWERS # 7

QUESTIONS & ANSWERS (Q&A)

ANA Garrisons

Amendment # 7

(Questions & Answers provided for informational purposes only)

17 August 2007

**W917PM-07-R-0086**

**RFI # 009**

Q. 1. Reference Amend. # 5, para 2.5 of section 01010; this para indicates that the power distribution system, i.e. the actual number of generators shall be split between the base bid and the optional items. This would conflict with para 9.4.1 (power plant) of section 01015 which defines the minimum number of generator to be supplied as 4MW. This minimum size of power distribution system covers the power requirement of both the base bid and the optional items. Please advise if the minimum power distribution system defined in para 9.4.1 shall be split between the base and optional items or should be all included under the base bid line item and the optional line item would be left blank.”

A. 1. Response: 4 MW is the minimum generator capacity required under the Base Bid for each of the projects. The proposer is stating that the 4 MW is the power required for both the Base Bid and Option Bid items. We cannot verify this without seeing the calculations. If 4 MW does in fact cover both the base and option bid, then additional generators will not be required when the option bids are exercised.

**RFI # 10**

Q. 1. Referenced to above subject, we would like to request to you, according to amend # 006 issued so far for the ANA Kunduz, is this applies for all three ANA or only for ANA Kunduz?

A. 1. Amendment # 0006 pertained to ANA Kunduz only.

(End of Summary of Changes)