

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE J	PAGE OF PAGES 1   2
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 27-Aug-2007	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY AFGHANISTAN ENGINEER DISTRICT US ARMY CORPS OF ENGINEERS KABUL APO AE 09356	CODE W917PM	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W917PM-07-R-0091	
		X	9B. DATED (SEE ITEM 11) 02-Aug-2007	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  This amendment is made to answer questions from prospective offerors.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  27-Aug-2007

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

## SECTION 00010 - SOLICITATION CONTRACT FORM

The Issued By organization has changed from  
AFGHANISTAN ENGINEER DISTRICT  
U.S. ARMY CORPS OF ENGINEERS, CMR 410 BOX  
APO 09096  
to  
AFGHANISTAN ENGINEER DISTRICT  
US ARMY CORPS OF ENGINEERS  
KABUL  
APO AE 09356

(End of Summary of Changes)

**The following items are applicable to this modification:**SECTION 00100 - BIDDING SCHEDULE/INSTRUCTIONS TO BIDDERS  
QUESTIONS & ANSWERS

Q1: In Option 2, the 30 KM road has a 20 cm sub base, 20 cm base and 10 cm surface is this correct?

A1: The base proposal requires the contractor to design and construct the pavement design to meet a 12,000kg vehicle per axle load as per the applicable standards listed in the proposal. In option two the contractor is asked to estimate the cost of paving the 30 Km of road within the villages.

Q2: In Option 1, the 30 KM of road has sub base, base and surface?

A2: The base proposal design should contain sub base, base course and surface course. In option 1, the contractor should include the added cost of using DBST for 30 Km through the villages.

Q3: In the proposal 68 KM of road is mentioned as 30 KM in Option 1 and 30 Km in Option 2 but the remaining 8 KM is not shown or written?

A3: This is incorrect. The base proposal calls an estimate for the design and construction of a 68 KM gravel road. The options are for the cost of asphalt paving or DBST through the villages for a total of 30 KM. These options may or may not be exercised by the government depending on the funding.

Q4 & 5: The number of culverts and washes is not known?

A4 & 5: The preliminary design provided should give an idea about the basic needs of the project. However, being a design-build contract it is the contractors responsibility to determine what hydraulic structures are needed and the location of these structures.