

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 03-Jul-2008	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY AFGHANISTAN ENGINEER DISTRICT US ARMY CORPS OF ENGINEERS KABUL APO AE 09356	CODE W917PM	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W917PM-08-R-0059	
		X	9B. DATED (SEE ITEM 11) 08-Jun-2008	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment for solicitation W917PM-08-R-0059 is to answer questions from the offerors.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 03-Jul-2008

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

The following have been added by full text:

QUESTIONS AND ANSWERS RFI # I

Questions & Answers Gamberi Garrison Phase II

RFI # I

Q.1. Where can we obtain water for use during construction? From the well or from the river?

A.1. PER THE RFP, THE U.S. GOVERNMENT IS NOT PROVIDING ANY TYPE OF UTILITIES TO SUPPORT THIS CONSTRUCTION, WHICH INCLUDES WATER.

Q.2. How close to the surface is the water if we bore a well?

A.2. IT IS THE KTR'S RESPONSIBILITY TO DETERMINE THIS WHICH IS PART OF THE D/B CONTRACT WHICH IS INHERENT ON PROVIDING WATER TO THE COMPOUND.

Q.3. Can we use some material (gravel for roads and soil for backfilling?) from the site which we have in the scope of work?

A.3. IF THE GRAVEL AND SOIL ARE DETERMINED TO ACCEPTABLE WITHIN THE TECHNICAL REQUIREMENTS OF THE CONTRACT THEN IT COULD BE USED.

Q.4. Can we build and create CMU blocks on site?

A.4. THERE NO RESTRICTION ON BUILDING CMU BLOCKS ON SITE. HOWEVER, THERE MUST BE A PLAN AND TESTING METHOD IDENTIFIED THAT DESCRIBES HOW THE CONTRACTOR WILL ENSURE THE CMU BLOCKS MEET THE MINIMUM REQUIREMENTS FOR STRUCTURAL INTEGRITY.

Q.5. Will security be by the contractor or the Corps of Engineers?

A.5. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING FOR THEIR SECURITY; YOU MUST TAKE THAT INTO ACCOUNT WHEN PREPARING YOUR PROPOSAL.

Q.6. What is the size of the total project area?

A.6. IAW WITH SECTION 01010, PARAGRAPH 4.1.1, THE SIZE OF THE PHASE II PROJECT AREA IS 300M X 1000M.

(End of Summary of Changes)