

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 14-Jul-2008	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)	
6. ISSUED BY AFGHANISTAN ENGINEER DISTRICT US ARMY CORPS OF ENGINEERS KABUL APO AE 09356	CODE W917PM	7. ADMINISTERED BY (If other than item 6) CODE See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W917PM-08-R-0085	
		X	9B. DATED (SEE ITEM 11) 30-Jun-2008	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.				
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) RLC Herat Barracks Expansion Delete Para 4.15 Logistics Buildings of Section 01010 Scope of Work in its entirety and add the revised Para 4.15 Logistics Buildings. Site Visit: 20 July 2008 between 0900 -1200; POC is Richard Klepfer; Cell number is 079-602-9015. All other terms and conditions remain unchanged.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		14-Jul-2008

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

4.15 LOGISTICS BUILDING

Design and construct 1 (one) 1,600 SM logistics building in accordance with the drawings in the appendices. It will have one 4M high bay door, on each side of the building, capable of backing in a Ford Light Tactical Vehicle (LTV). It will contain one office with an area of 12 square meters. Provide one storage room of 20 square meters with a locking door. The rest of the space will be open space and shall have 5M min. floor to ceiling clearance. Columns are acceptable. Provide a split package heating and cooling system in the office only. Provide janitor's closet with mop sink."

QUESTIONS & ANSWERS (Q&A)
RLC Harat Barracks Expansion
W917PM-08-R-0085

(Questions & Answers provided for informational purposes only)

If any Government responses indicate a change to the technical proposal, it is not official until
and amendment is issued)

14 July 2008

Question-Q

Answer-A

Q. In your RFP/Solicitation letter mentioning; Description 003AG-Logistic Building for General Storage, Page 4. But in your Drawings and Section 01010 of SOW, sub-title "e", page 45, it is not mentioned the Logistic Building for General Storage.

A. Yes, the Logistic Building is for General Storage

Q. Reviewing of SOW we understand that the Project is under construction in Phase-I, As per Item/Sub-section 2.5, 2.6 and 2.7, page 47 of SOW, we are going to estimate in our proposal the connection of building utilities to the existing utilities is not more than 20 mts. length for water supply, waste water and electrical distribution system. Please confirm that the existing utilities can hold the additional.

A. Yes, existing utilities can handle the additional load.

Q. Can you please advise us what kind of HVAC system in current used by contractor in Phase-I.

A. We have 2 different models of split-packs. The larger ones are LG S186GH, and the smaller one is BEKO R51M(C)E. (See section 1010, para 4.15 located in Amendment 0002.

Q. Is the Due Date is extended? because we check your website there was no amendment for the due date. Can advise us when is the final Due Date.

A. Proposals are due 23 July 2008.

Q. For how many personnel we need the barracks space to submit our bid?

A. 350 Personnel

Q. The ammunition supply point is mentioned in the BOQ but the couldn't find the its area in the statement of work could you please advice.

A. See section 1010 para 4.17.